



cleargold
water restoration company limited

Independent Laboratory Tests

IG MicroMed Environmental

190 - 12860 Clarke Place, Richmond, BC V6V 2H1

Tel: (604) 279-0666 Fax: (605) 279-0663

Product Sampled: A water treatment reactor was challenged with Escherichia coli in moderate counts. This was to evaluate the efficiency of bacterial reductions over time.

Sample	Escherichia coli (cfu/ml)
Neat	600
0 Minutes	0
5 Minutes	0
10 Minutes	0
30 Minutes	0
1 Hour	0
2 Hours	0
3 Hours	0
4 Hours	0

