



cleargold
water restoration company limited

Independent Laboratory Tests

IG MicroMed Environmental

190 - 12860 Clarke Place, Richmond, BC V6V 2H1

Tel: (604) 279-0666 Fax: (605) 279-0663

Product Sampled: A water treatment reactor was challenged with Escherichia coli in moderate counts. This was to evaluate the efficiency of bacterial reductions over time.

Note: The results show a marked reduction in bacterial numbers. The initial challenge was considered to be excessive, however the reduction was quite marked.

Sample	Escherichia coli (cfu/ml)
Neat	200,000
1 Minutes	8,000
5 Minutes	2,000
30 Minutes	800
1 Hour	800
2 Hours	600

