



cleargold
water restoration company limited

IG MicroMed Environmental

190 - 12860 Clarke Place, Richmond, BC V6V 2H1

Tel: (604) 279-0666 Fax: (605) 279-0663

Product Sampled: A water treatment reactor was challenged with *Pseudomonas aeruginosa* in moderate counts. This was to evaluate the efficiency of bacterial reductions over time.

Sample	<i>Pseudomonas aeruginosa</i> (cfu/ml)
Neat	4,000,000,000
No Reactor	300,000
Reactor Free Flow	60,000
5 Minutes	3,000
15 Minutes	800
30 Minutes	20

